

ADDENDUM #2  
Bureau of Motor Vehicles  
Concrete Sidewalk Replacement  
September 30, 2014

**A. Questions received on 30 Sept 2014:**

- 1 – Are bonds required for the job.
  - No, unless your total bid exceeds \$125,000.00, then Bid, Performance and Payment Bonds are required by statute.
- 2 – Will we be allowed to let the visitors and employees walk on gravel?
  - No. The surface needs to be firm and stable. Use of a compacted “Tri-pack” product to maintain a 5’ wide path from the door to the parking lot is acceptable.
- 3 – The lower area has a card reader that accesses only one door. How will access to the lower level be handled?
  - BMV will temporarily disable the use of the card reader to allow entry through any door. Coordinate time needed with BMV.
- 4 – Is all of the “curb” area to be slip form including the integral curb at the lower level?
  - The intent is to provide new curb where existing curb was. The integral curb at the lower level is acceptable.

**B. Due to the timing of the questions, in order to maintain the required 72 hour minimum between Addendum and Bid Opening, the Bid Opening will be rescheduled to 2:00 PM on Friday, 03 October 2014 at the original location.**

**C. Be sure to acknowledge this Addendum #2 on your bid form in the space provided.**

-

**END of Addendum #2**