

ADDENDUM

Date: December 17, 2014

To: Prospective Bidders

Re: Addendum No. 1 to the Bidding Documents for:


Athletic Center Bleacher Replacements
SMCC Campus
South Portland, Maine

This Addendum forms a part of the Contract Documents and modifies the original Bidding documents dated December 5, 2014

This Addendum consists of 2 pages.



Robert J. Foster AIA
Architect



CHANGES TO SPECIFICATIONS:

1. Specification Section 00 21 13 Instruction to Bidders. Add paragraph 3.11. "3.11 Bidders shall include with their bid a written description and/or brochures for the two bleacher systems proposed for the bleacher replacement project including; the primary motor controlled bleacher system and the portable bleacher system."
2. Specification Section 00 72 13 General Conditions. Clarification – The bidding Contractors shall carry all insurance requirements stipulated in section 14 of the General Conditions, including Pollution Liability Insurance.
3. Specification Section 12660 Telescopic Gym Seating System. Modify paragraph 2.07 h. to read: "Electrical – Seating Manufacturer shall provide all wiring within seating bank, including pendant control. Motors, housing, and wiring shall be install and grounded in complete accord with the National Electrical Code. The Owner shall provide the required power to locations at the walls at the approximate center of the 3 major bleacher banks. The Seating Manufacturer shall coordinate all required connections fully with the Owner's Electrician."
4. Specification Section 00 11 13 Notice to Contractors. Remainder – The bids will be opened and read aloud at the small conference room at the Fort/Security Building at SMCC at 2:00 pm on December 23, 2014.

END