

ADDENDUM #2

Date: July 26, 2016

Re: Asbestos Removal at the Center Building of the AMHI Campus

From: CES, Inc.

P.O. Box 639

Brewer, ME 04412

Owner Project No:

A/E Project No. 10289.004

To: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original bidding documents dated June 2016. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of two (2) page and is being issued to meet the requirements of the Project Manual.

CHANGES TO BIDDING/CONTRACT REQUIREMENTS:

The following questions have been submitted by prospective bidders:

- **What type of caps are needed on remaining fire suppression piping?**

Rubber caps with a hose clamp are sufficient, the intent of the cap is to prevent debris accumulation within the remaining system.

- **The ACM Table distributed with Addendum # 1 has an inconsistency from the columns to the totals listed, which is the correct quantity?**

Quantities provided in the project manual are estimates. The Contractor is responsible for determining actual quantities of materials included as part of the abatement work and as indicated within the project manual and on project drawings.

- **Can you confirm that removal and disposal of items within the building is limited to items that are loose and hanging and not attached to the wall surfaces unless noted (pictures, speakers, clocks, etc. mounted to walls don't need to be removed)?**

Removal includes items not mechanically connected to floor, wall, or ceiling surfaces, unless those items require removal to access other items within the scope of work, in which case they shall be removed and disposed of by the Contractor.

- **Have the laydown areas been determined/approved?**

The laydown/parking area will be located on the west side of the building. Capitol Police have been to the Site and have expressed an interest in working with the Contractor to provide space for the needs of the project. However, a "fire" travel lane to the rear of building must remain clear. Vehicles and other equipment may be parked in this area provided they are positioned to allow clear access.

- **Will weekly certified payroll be required?**

No.