



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION

PAUL R. LEPAGE
GOVERNOR

PATRICIA W. AHO
COMMISSIONER

**MSAD #20
Aroostook County
Fort Fairfield, Maine
A-1063-71-A-N**

**Departmental
Findings of Fact and Order
Air Emission License
After-The-Fact**

After review of the air emissions license application, staff investigation reports and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 M.R.S.A., §344 and §590, the Department finds the following facts:

I. REGISTRATION

A. Introduction

1. MSAD #20 has applied for an Air Emission License permitting operation of emission sources associated with their educational facility.
2. The equipment addressed in this license is located at 28 High School Drive, Fort Fairfield, ME

B. Emission Equipment

The following equipment is addressed in this air emission license:

Boilers

<u>Equipment</u>	<u>Maximum Capacity (MMBtu/hr)</u>	<u>Maximum Firing Rate (Gal/hr)</u>	<u>Fuel Type, % Sulfur</u>	<u>Install. Date</u>	<u>Stack #</u>
Boiler #1	3.1	22.13	#2 Fuel Oil, 0.5%	1993	1
Boiler #2	3.1	22.13	#2 Fuel Oil, 0.5%	1997	1
Boiler #3*	3.0	.34 TPH	Wood	2011	2
Boiler #4	2.0	13.91	#2 Fuel Oil, 0.5%	1991	3
Boiler #5	2.0	13.91	#2 Fuel Oil, 0.5%	1991	3

*New equipment – not yet installed

AUGUSTA
17 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0017
(207) 287-7688 FAX: (207) 287-7826
RAY BLDG., HOSPITAL ST.

BANGOR
106 HOGAN ROAD, SUITE 6
BANGOR, MAINE 04401
(207) 941-4570 FAX: (207) 941-4584

PORTLAND
312 CANCO ROAD
PORTLAND, MAINE 04103
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE
1235 CENTRAL DRIVE, SKYWAY PARK
PRESQUE ISLE, MAINE 04679-2094
(207) 764-0477 FAX: (207) 760-3143

Generators

<u>Equipment</u>	<u>KW</u>	<u>Firing Rate (Gal/hr)</u>	<u>Fuel Type, % sulfur</u>	<u>Install. Date</u>	<u>Stack #</u>
Emerg. Gener.	75	5.33	Diesel, 0.05% S	1981	4

C. Application Classification

MSAD #20 is classified as an existing source that is applying for its first air emission license, after the fact.

The new source is considered a major source based on whether or not expected emissions exceed the "Significant Emission Levels" as defined in the Department's regulations. The emissions for the new source are determined by the maximum future license allowed emissions, as follows:

<u>Pollutant</u>	<u>Max. Future License (TPY)</u>	<u>Sig. Level (TPY)</u>
PM	9.4	100
PM ₁₀	9.4	100
SO ₂	22.6	100
NO _x	17.1	100
CO	9.9	100
VOC	0.4	50

The Department has determined the facility is a minor source and the application has been processed through *Major and Minor Source Air Emission License Regulations*, 06-096 CMR 115 (as amended).

II. BEST PRACTICAL TREATMENT (BPT)

A. Introduction

In order to receive a license the applicant must control emissions from each unit to a level considered by the Department to represent Best Practical Treatment (BPT), as defined in *Definitions Regulation*, 06-096 CMR 100 (as amended). Separate control requirement categories exist for new and existing equipment as well as for those sources located in designated non-attainment areas.

BPT for new sources and modifications requires a demonstration that emissions are receiving Best Available Control Technology (BACT), as defined in *Definitions Regulation*, 06-096 CMR 100 (as amended). BACT is a top-down approach to selecting air emission controls considering economic, environmental and energy impacts.

B. Boilers #1, #2, #4 and #5

MSAD #20 operates Boilers #1 and #2 for heat. The boilers are each rated at 3.1 MMBtu per hour and fire #2 fuel oil. Boiler #1 was installed in 1993; Boiler #2 in 1997. Both boilers exhaust through common Stack #1.

Due to the size and year of installation, neither Boiler #1 nor Boiler #2 is subject to the New Source Performance Standards (NSPS) 40 CFR Part 60, Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBtu per hour manufactured after June 9, 1989.

MSAD #20 operates Boilers #4 and #5 for heat. The boilers are each rated at 2.0 MMBtu per hour and fire #2 fuel oil. Both boilers were installed in 1991, and exhaust through common Stack #3.

Due to their size, neither Boiler #4 nor Boiler #5 is subject to the New Source Performance Standards (NSPS) 40 CFR Part 60, Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBtu per hour manufactured after June 9, 1989.

1. BACT Findings

The BACT emission limits for each of the boilers were based on the following:

PM/PM ₁₀	- 0.12 lb/MMBtu based on 06-096 CMR 103;
SO ₂	- based on firing ASTM D396 #2 fuel oil (0.5% sulfur
NO _x	- 0.3 lb/MMBtu based on BPT
CO	- 5 lb/1000 gal, AP-42, Table 1.3-1, dated 5/10
VOC	- 0.2 lb/1000 gal, AP-42, Table 1.3-3, dated 5/10
Opacity	- visible emissions from the boilers shall not exceed 20% opacity on a 6 minute block average, except for no more than one (1) six (6) minute block average in a 3 hour period.

The BPT emission limits for the boilers are the following:

Unit	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler # 1	0.37	0.37	1.56	0.93	0.11	0.01
Boiler # 2	0.37	0.37	1.56	0.93	0.11	0.01
Boiler # 4	0.23	0.23	0.98	0.58	0.07	0.01
Boiler # 5	0.23	0.23	0.98	0.58	0.07	0.01

Until December 31, 2015, the fuel oil fired in Boilers #1, #2, #4 and #5 shall be ASTM D396 compliant #2 fuel oil (maximum sulfur content of 0.5% by weight). Per 38 MRSA §603-A(2)(A)(3), beginning January 1, 2016, the facility shall fire #2 fuel oil with a maximum sulfur content limit of 0.005% by weight (50 ppm), and beginning January 1, 2018, the facility shall fire #2 fuel oil with a maximum sulfur content limit of 0.0015% by weight (15 ppm).

Periodic Monitoring

Periodic monitoring for both boilers shall include recordkeeping to document fuel use both on a monthly and 12-month rolling total basis. Documentation shall include the type of fuel used and sulfur content of the fuel.

C. Boiler #3

Boiler #3 is rated at 3.1 MMBtu per hour firing wood chips (50% moisture). This boiler will be installed in the winter of 2011/2012.

Because of its size, Boiler #3 is not subject to the New Source Performance Standards (NSPS) 40 CFR Part 60, Subpart Dc *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBtu per hour manufactured after June 9, 1989

A summary of the BPT analysis for Boiler #3 is the following:

1. MSAD #20 shall use the following formula, when necessary, to convert fuel use records to 50% moisture:

$$\text{Tons Wood at 50\%} = (\text{Tons Wood at M\%}) \times [(100-M)/50]$$

where M = the moisture content of the actual wood fired

2. MSAD #20 shall continuously operate the multicyclone on Boiler #3 when Boiler #3 is in operation.
3. *Fuel Burning Equipment Particulate Emission Standard*, 06-096 CMR 103 (as amended) regulates PM emission limits. However, BACT has determined a more stringent limit of 0.25 pounds of particulate matter per million BTU is appropriate and shall be used. The PM₁₀ limits are derived from the PM limits.
4. SO₂, NO_x, CO, and VOC emission limits are based upon AP-42 data dated 9/03.
5. Visible emissions from Boiler #3 shall not exceed 30% opacity on a six (6) minute block average, except for no more than two (2) six (6) minute block averages in a continuous 3-hour period.

D. 40 CFR Part 63 Subpart JJJJJ

Boilers #1, #2, #3, #4 and #5 are subject to the *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources* (40 CFR Part 63 Subpart JJJJJ). Boilers #1, #2, #4 and #5 are considered existing oil boilers, rated at less than 10 MMBtu/hr. Boiler #3 is considered a new biomass boiler, rated at less than 10 MMBtu/hr.

For informational purposes, a summary of the current applicable federal 40 CFR Part 63 Subpart JJJJJ requirements is listed below. At this time, the Maine Department of Environmental Protection has not taken delegation of this area source MACT (Maximum Achievable Control Technology) rule promulgated by EPA, however MSAD #20 is still subject to the requirements. Notification forms and additional rule information can be found on the following website: <http://www.epa.gov/ttn/atw/boiler/boilerpg.html>.

a. Compliance Dates, Notifications, and Work Practice Requirements

i. Initial Notification of Compliance

An Initial Notification shall be submitted to EPA no later than September 17, 2011. [40 CFR Part 63.11225(a)(2)]

ii. Boiler Tune-Up Program – Initial and Biennial

- (a) A boiler tune-up program shall be implemented to include the tune-up of applicable boilers by March 21, 2012. [40 CFR Part 63.11196(a)(1)]

- (b) The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:
1. As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted; however, the burner must be inspected at least once every 36 months. [40 CFR Part 63.11223(b)(1)]
 2. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 CFR Part 63.11223(b)(2)]
 3. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. [40 CFR Part 63.11223(b)(3)]
 4. Optimize total emissions of CO, consistent with manufacturer's specifications. [40 CFR Part 63.11223(b)(4)]
 5. Measure the concentration in the effluent stream of CO in parts per million (ppm), by volume, and oxygen in volume percent, before and after adjustments are made. [40 CFR Part 63.11223(b)(5)]
 6. If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within one week of start-up. [40 CFR Part 63.11223(b)(7)]
- (c) A Notification of Compliance Status shall be submitted to EPA no later than 120 days after conducting the initial boiler tune-up. [40 CFR Part 63.11225(a)(4) and 40 CFR Part 63.11214(b)]
- (d) The facility shall implement a biennial boiler tune-up program after the initial tune-up and initial compliance report has been submitted.
1. Each biennial tune-up shall be conducted no more than 25 months after the previous tune-up. [40 CFR Part 63.11223(a)]
 2. The biennial report shall be maintained onsite and submitted to EPA, if requested. The report shall contain the concentration of CO in the effluent stream (ppmv) and oxygen in volume percent, measured before and after the boiler tune-up, a description of any corrective actions taken as part of the tune-up of the boiler, and the type and amount of fuel used over the 12 months prior to the biennial tune-up of the boiler. [40 CFR Part 63.11223(b)(6)] The biennial compliance report shall also include the company name and address; a compliance statement signed by a responsible official certifying truth, accuracy, and completeness; and a description of any deviations and corrective actions. [40 CFR Part 63.11225(b)]

b. Recordkeeping

Records shall be maintained consistent with the requirements of 40 CFR Part 63 Subpart JJJJJ including the following [40 CFR Part 63.11225(c)]: copies of notifications and reports with supporting compliance documentation; identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned; documentation of fuel type(s) used monthly by each boiler; the occurrence and duration of each malfunction of the boiler; and actions taken during periods of malfunction to minimize emissions and actions taken to restore the malfunctioning boiler to its usual manner of operation. Records shall be in a form suitable and readily available for expeditious review.

E. Emergency Generators

MSAD #20 operates one emergency generator, rated at 75 KW, firing diesel fuel. The generator was manufactured in 1981.

1. BACT Findings

The BACT emission limits for the generator are based on the following:

Diesel

PM/PM₁₀ – 0.12 lb/MMBtu from AP-42 Table 3.3-1 (dated 10/96)
SO₂ – based on firing 0.05% sulfur, 0.05 lb/MMBtu
NO_x – 4.41 lb/MMBtu, AP-42, Table 3.3-1 (dated 10/96);
CO – 0.95 lb/MMBtu, AP-42, Table 3.3-1 (dated 10/96);
VOC – 0.35 lb/MMBtu, AP-42, Table 3.3-1 (dated 10/96);
Opacity – visible emissions from the diesel emergency generator shall not exceed 20% opacity on a 6 minute block average, except for no more than two (2) six (6) minute block averages in a 3 hour period.

<u>Unit</u>	<u>PM</u> <u>(lb/hr)</u>	<u>PM₁₀</u> <u>(lb/hr)</u>	<u>SO₂</u> <u>(lb/hr)</u>	<u>NO_x</u> <u>(lb/hr)</u>	<u>CO</u> <u>(lb/hr)</u>	<u>VOC</u> <u>(lb/hr)</u>
Emergency Generator	0.09	0.09	0.04	3.22	0.69	0.26

The emergency generator shall be limited to 500 hours of operation a year, based on a 12-month rolling total. MSAD #20 shall keep records of the hours of operation for the unit.

2. 40 CFR Part 63, Subpart ZZZZ

The federal regulation 40 CFR Part 63, Subpart ZZZZ, *National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines* is not applicable to the emergency generator listed above. The unit is considered an existing, emergency stationary reciprocating internal combustion engine at an area HAP source, however it is considered exempt from the requirements of Subpart ZZZZ since it is categorized as a residential, commercial, or institutional emergency engine.

F. Annual Emissions

MSAD #20 shall be restricted to the following annual emissions, based on a 12-month rolling total:

Total Licensed Annual Emissions for the Facility
Tons per Year
(Used to calculate the annual license fee)

	PM	PM ₁₀	SO ₂	NO _x	CO	VOC
Boilers #1	1.63	1.63	6.83	4.07	0.48	0.02
Boiler # 2	1.63	1.63	6.83	4.07	0.48	0.02
Boiler # 3	3.39	3.39	0.34	2.99	8.15	0.23
Boiler # 4	1.02	1.02	4.30	2.56	0.30	0.01
Boiler # 5	1.02	1.02	4.30	2.56	0.30	0.01
Emerg. Generator	0.02	0.02	0.04	3.22	0.69	0.06
Total TPY	8.7	8.7	22.6	17.1	9.9	0.4

III. AMBIENT AIR QUALITY ANALYSIS

According to 06-096 CMR 115, the level of air quality analyses required for a minor new source shall be determined on a case-by case basis. Based on the information available in the file and the similarity to existing sources, Maine Ambient Air Quality Standards (MAAQS) will not be violated by this source.

ORDER

Based on the above Findings and subject to conditions listed below, the Department concludes that the emissions from this source:

- will receive Best Practical Treatment,
- will not violate applicable emission standards,
- will not violate applicable ambient air quality standards in conjunction with emissions from other sources.

The Department hereby grants Air Emission License A-1063-71-A-N subject to the following conditions:

Severability. The invalidity or unenforceability of any provision, or part thereof, of this License shall not affect the remainder of the provision or any other provisions. This License shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted.

STANDARD CONDITIONS

- (1) Employees and authorized representatives of the Department shall be allowed access to the licensee's premises during business hours, or any time during which any emissions units are in operation, and at such other times as the Department deems necessary for the purpose of performing tests, collecting samples, conducting inspections, or examining and copying records relating to emissions (38 M.R.S.A. §347-C).
- (2) The licensee shall acquire a new or amended air emission license prior to commencing construction of a modification, unless specifically provided for in Chapter 115. [06-096 CMR 115]
- (3) Approval to construct shall become invalid if the source has not commenced construction within eighteen (18) months after receipt of such approval or if construction is discontinued for a period of eighteen (18) months or more. The Department may extend this time period upon a satisfactory showing that an extension is justified, but may condition such extension upon a review of either the control technology analysis or the ambient air quality standards analysis, or both. [06-096 CMR 115]

- (4) The licensee shall establish and maintain a continuing program of best management practices for suppression of fugitive particulate matter during any period of construction, reconstruction, or operation which may result in fugitive dust, and shall submit a description of the program to the Department upon request. [06-096 CMR 115]
- (5) The licensee shall pay the annual air emission license fee to the Department, calculated pursuant to Title 38 M.R.S.A. §353-A. [06-096 CMR 115]
- (6) The license does not convey any property rights of any sort, or any exclusive privilege. [06-096 CMR 115]
- (7) The licensee shall maintain and operate all emission units and air pollution systems required by the air emission license in a manner consistent with good air pollution control practice for minimizing emissions. [06-096 CMR 115]
- (8) The licensee shall maintain sufficient records to accurately document compliance with emission standards and license conditions and shall maintain such records for a minimum of six (6) years. The records shall be submitted to the Department upon written request. [06-096 CMR 115]
- (9) The licensee shall comply with all terms and conditions of the air emission license. The filing of an appeal by the licensee, the notification of planned changes or anticipated noncompliance by the licensee, or the filing of an application by the licensee for a renewal of a license or amendment shall not stay any condition of the license. [06-096 CMR 115]
- (10) The licensee may not use as a defense in an enforcement action that the disruption, cessation, or reduction of licensed operations would have been necessary in order to maintain compliance with the conditions of the air emission license. [06-096 CMR 115]
- (11) In accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department, the licensee shall:
 - A. perform stack testing to demonstrate compliance with the applicable emission standards under circumstances representative of the facility's normal process and operating conditions:

1. within sixty (60) calendar days of receipt of a notification to test from the Department or EPA, if visible emissions, equipment operating parameters, staff inspection, air monitoring or other cause indicate to the Department that equipment may be operating out of compliance with emission standards or license conditions; or
 2. pursuant to any other requirement of this license to perform stack testing.
- B. install or make provisions to install test ports that meet the criteria of 40 CFR Part 60, Appendix A, and test platforms, if necessary, and other accommodations necessary to allow emission testing; and
- C. submit a written report to the Department within thirty (30) days from date of test completion.
- [06-096 CMR 115]
- (12) If the results of a stack test performed under circumstances representative of the facility's normal process and operating conditions indicate emissions in excess of the applicable standards, then:
- A. within thirty (30) days following receipt of such test results, the licensee shall re-test the non-complying emission source under circumstances representative of the facility's normal process and operating conditions and in accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department; and
 - B. the days of violation shall be presumed to include the date of stack test and each and every day of operation thereafter until compliance is demonstrated under normal and representative process and operating conditions, except to the extent that the facility can prove to the satisfaction of the Department that there were intervening days during which no violation occurred or that the violation was not continuing in nature; and
 - C. the licensee may, upon the approval of the Department following the successful demonstration of compliance at alternative load conditions, operate under such alternative load conditions on an interim basis prior to a demonstration of compliance under normal and representative process and operating conditions.
- [06-096 CMR 115]
- (13) Notwithstanding any other provisions in the State Implementation Plan approved by the EPA or Section 114(a) of the CAA, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any statute, regulation, or Part 70 license requirement. [06-096 CMR 115]

- (14) The licensee shall maintain records of malfunctions, failures, downtime, and any other similar change in operation of air pollution control systems or the emissions unit itself that would affect emission and that is not consistent with the terms and conditions of the air emission license. The licensee shall notify the Department within two (2) days or the next state working day, whichever is later, of such occasions where such changes result in an increase of emissions. The licensee shall report all excess emissions in the units of the applicable emission limitation. [06-096 CMR 115]
- (15) Upon written request from the Department, the licensee shall establish and maintain such records, make such reports, install, use and maintain such monitoring equipment, sample such emissions (in accordance with such methods, at such locations, at such intervals, and in such a manner as the Department shall prescribe), and provide other information as the Department may reasonably require to determine the licensee's compliance status. [06-096 CMR 115]

SPECIFIC CONDITIONS

(16) **Boilers #1, #2, #3, #4 and #5**

A Fuel

1. Boilers #1, #2, #4 and #5 shall fire #2 fuel oil; Boiler #3 shall fire wood chips.
2. Until December 31, 2015, the #2 fuel oil fired in the boiler shall be ASTM D396 compliant (max. sulfur content of 0.5% by weight). [06-096 CMR 115, BPT]
3. Beginning January 1, 2016, the facility shall fire #2 fuel oil with a maximum sulfur content limit of 0.005% by weight (50 ppm). [38 MRSA §603-A(2)(A)(3)]
4. Beginning January 1, 2018, the facility shall fire #2 fuel oil with a maximum sulfur content limit of 0.0015% by weight (15 ppm). [38 MRSA §603-A(2)(A)(3)]
5. Compliance shall be demonstrated by fuel records from the supplier showing the quantity, type, and the percent sulfur of the fuel delivered (if applicable). Records of annual fuel use shall be kept on a monthly and calendar year basis. [06-096 CMR 115, BPT]

B. Emissions shall not exceed the following:

<u>Unit</u>	<u>Pollutant</u>	<u>lb/MMBtu</u>	<u>Origin and Authority</u>
Boiler # 1	PM	0.12	06-096 CMR 103(2)(B)(1)(a)
Boiler # 2	PM	0.12	06-096 CMR 103(2)(B)(1)(a)
Boiler # 3	PM	0.25	06-096 CMR 03(2)(B)(1)(a), BACT

C. Emissions shall not exceed the following [06-096 CMR 115, BPT]:

<u>Unit</u>	<u>PM (lb/hr)</u>	<u>PM₁₀ (lb/hr)</u>	<u>SO₂ (lb/hr)</u>	<u>NO_x (lb/hr)</u>	<u>CO (lb/hr)</u>	<u>VOC (lb/hr)</u>
Boiler # 1	0.37	0.37	1.56	0.93	0.11	0.01
Boiler # 2	0.37	0.37	1.56	0.93	0.11	0.01
Boiler # 3	0.78	0.78	0.08	0.68	1.86	0.05
Boiler # 4	0.23	0.23	0.98	0.58	0.07	0.01
Boiler # 5	0.23	0.23	0.98	0.58	0.07	0.01

D. Visible Emissions

1. Visible emissions from each boiler firing #2 fuel oil shall not exceed 20% opacity on a 6 minute block average, except for no more than one (1) six (6) minute block average in a 3 hour period. [06-096 CMR 101]
2. Visible emissions from Boiler #3 firing wood chips shall not exceed 30% opacity on a 6 minute block average basis, except for no more than two (2) six (6) minute block averages in a 3 hour period. [06-096 CMR 101]

(17) **Emergency Generator**

- A. The Emergency Generator is limited to 500 hours per year total operation, based on a 12- month rolling total. Compliance shall be demonstrated by a written log of all generator operating hours. [06-096 CMR 115]
- B. The fuel oil sulfur content for the Emergency Generator shall be limited to 0.0015% sulfur. Compliance shall be demonstrated by fuel records from the supplier documenting the type of fuel delivered and the sulfur content of the fuel. [06-096 CMR 115, BPT]

C. Emissions shall not exceed the following [06-096 CMR 115, BPT]:

<u>Unit</u>	<u>PM (lb/hr)</u>	<u>PM₁₀ (lb/hr)</u>	<u>SO₂ (lb/hr)</u>	<u>NO_x (lb/hr)</u>	<u>CO (lb/hr)</u>	<u>VOC (lb/hr)</u>
Emergency Generator	0.09	0.09	0.04	3.22	0.69	0.26

D. Visible Emissions

1. Visible emissions from the Emergency Generators shall not exceed 20% opacity on a 6 minute block average, except for no more than two (2) six (6) minute block averages in a 3 hour period. [06-096 CMR 101]

(18) MSAD #20 shall notify the Department within 48 hours and submit a report to the Department on a quarterly basis if a malfunction or breakdown in any component causes a violation of any emission standard (38 M.R.S.A. §605).

DONE AND DATED IN AUGUSTA, MAINE THIS 1st DAY OF November, 2011.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY: Melanie [Signature] for
PATRICIA W. AHO, COMMISSIONER

The term of this license shall be five (5) years from the signature date above.

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application: 08/09/2011

Date of application acceptance: 08/22/2011

Date filed with the Board of Environmental Protection:

This Order prepared by N. Lynn Cornfield, Bureau of Air Quality.

