



STATE OF MAINE  
DEPARTMENT OF ENVIRONMENTAL PROTECTION



PAUL R. LEPAGE  
GOVERNOR

PATRICIA W. AHO  
COMMISSIONER

**Hissong Ready-Mix & Aggregates, LLC**  
**York County**  
**Eliot, Maine**  
**A-1025-71-B-R**

**Departmental**  
**Findings of Fact and Order**  
**Air Emission License**  
**Renewal**

**FINDINGS OF FACT**

After review of the air emission license renewal application, staff investigation reports, and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 Maine Revised Statutes Annotated (M.R.S.A.), §344 and §590, the Maine Department of Environmental Protection (Department) finds the following facts:

**I. REGISTRATION**

A. Introduction

1. Hissong Ready-Mix & Aggregates, LLC (Hissong), located in Eliot, Maine has applied to renew their Air Emission License, permitting the operation of their concrete batch plant
2. The main office is located at 50 MacLellan Lane, Eliot, ME.

B. Emission Equipment

The following equipment is addressed in this Air Emission License:

**Heating Equipment**

<u>Equipment</u>	<u>Maximum Capacity</u> MMBtu/hr	<u>Fuel Type</u>	<u>Maximum Firing Rate</u>
Boiler #1 (Water Heater)	2.8	Distillate fuel, 0.5% S	20 gal/hr

**Concrete Plant**

<u>Equipment</u>	<u>Production Rate</u> (cubic yards/hour)	<u>Control Devices</u>
Concrete Batch Plant	200	RA 140 Dust Collection Unit

C. Definitions

*Distillate Fuel* means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396, diesel fuel oil numbers 1 or 2, as defined in ASTM D975, kerosene, as defined in ASTM D3699, biodiesel as defined in ASTM D6751, or biodiesel blends as defined in ASTM D7467.

D. Application Classification

The application for Hissong does not include the licensing of increased emissions or the installation of new or modified equipment. Therefore, the license is considered to be a renewal of currently licensed emission units only and has been processed through *Major and Minor Source Air Emission License Regulations*, 06-096 Code of Maine Rules (CMR) 115 (as amended).

The facility is licensed below the major source thresholds for criteria pollutants and is considered a natural minor.

The facility is licensed below the major source thresholds for hazardous air pollutants (HAP) and is considered an area source of HAP.

**II. BEST PRACTICAL TREATMENT**

A. Introduction

In order to receive a license the applicant must control emissions from each unit to a level considered by the Department to represent Best Practical Treatment (BPT), as defined in *Definitions Regulation*, 06-096 CMR 100 (as amended). Separate control requirement categories exist for new and existing equipment.

BPT for existing emissions equipment means that method which controls or reduces emissions to the lowest possible level considering:

- the existing state of technology;
- the effectiveness of available alternatives for reducing emissions from the source being considered; and
- the economic feasibility for the type of establishment involved.

B. Concrete Batch Plant

The concrete batch plant is rated at 200 cubic yards per hour and includes two silos (Silo #1 and Silo #2).

To meet the requirements of BPT for control of particulate matter (PM) emissions from the cement silo(s), particulate emissions shall be vented through a baghouse maintained for 99% removal efficiency. Visible emissions from each cement silo baghouse are limited to no greater than 10% opacity on a six (6)-minute block average basis except for no more than one (1), six (6)-minute block average in a one (1)-hour period. The facility shall take corrective action if visible emissions from the baghouses exceed 5% opacity.

All components of the concrete batch plant shall be maintained so as to prevent PM leaks. Visible emissions from concrete batching operations shall not exceed 20% opacity on a six (6)-minute block average basis except for no more than one (1), six (6)-minute block average in a one (1)-hour period.

C. Boiler #1

Boiler #1 is an Inferno-O-Therm Water Boiler, manufactured and installed in 2009, and has a maximum capacity of 2.8 MMBtu/hr, firing distillate fuel.

1. BPT Findings

The BPT emission limits for the boiler were based on the following:

- PM/PM<sub>10</sub> – 0.08 lb/MMBtu based on 06-096 CMR 103
- SO<sub>2</sub> – based on firing distillate fuel (0.5% sulfur by weight)
- NO<sub>x</sub> – 20 lb/1000 gal based on AP-42, Table 1.3-1, dated 5/10
- CO – 5 lb/1000 gal based on AP-42, Table 1.3-1, dated 5/10
- VOC – 0.34 lb/1000 gal based on AP-42, Table 1.3-3, dated 5/10
- Opacity – 06-096 CMR 101, previous BACT

The BPT emission limits for the boiler are the following:

<u>Unit</u>	<u>PM</u> (lb/hr)	<u>PM<sub>10</sub></u> (lb/hr)	<u>SO<sub>2</sub></u> (lb/hr)	<u>NO<sub>x</sub></u> (lb/hr)	<u>CO</u> (lb/hr)	<u>VOC</u> (lb/hr)
Boiler #1	0.22	0.22	1.41	0.84	0.10	0.01

Visible emissions from the boiler shall not exceed 20% opacity on a six (6)-minute block average, except for no more than one (1), six (6)-minute block average in a three (3)-hour period.

Hissong shall be limited to 100,000 gallons per year of distillate fuel.

Prior to July 1, 2016, or by the date otherwise stated in 38 MRSA §603-A(2)(A)(3), the distillate fuel fired in Boiler #1 shall have a maximum sulfur content of 0.5% by weight. Per 38 MRSA §603-A(2)(A)(3), beginning July 1, 2016, or on the date specified in the statute, the facility shall fire distillate fuel with a maximum sulfur content limit of 0.005% by weight (50 ppm), and beginning January 1, 2018, or on the date specified in the statute, the facility shall fire distillate fuel with a maximum sulfur content limit of 0.0015% by weight (15 ppm). The specific dates contained in this paragraph reflect the current dates in the statute as of the effective date of this license; however, if the statute is revised, the facility shall comply with the revised dates upon promulgation of the statute revision.

2. Periodic Monitoring

Periodic monitoring for the boiler shall include recordkeeping to document fuel use both on a monthly and calendar year total basis. Documentation shall include the type of fuel used and sulfur content of the fuel.

3. New Source Performance Standards

Due to the size, the boiler is not subject to the New Source Performance Standards (NSPS) 40 CFR Part 60, Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBtu/hr manufactured after June 9, 1989.

4. National Emission Standards for Hazardous Air Pollutants

Boiler #1 is subject to the *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources* (40 CFR Part 63 Subpart JJJJJ). The unit is considered an existing oil fired boiler, rated less than 10 MMBtu/hr.

A summary of the currently applicable federal 40 CFR Part 63 Subpart JJJJJ requirements is listed below. At this time, the Department has not taken delegation of this area source MACT (Maximum Achievable Control Technology) rule promulgated by EPA, however Hissong is still subject to the requirements. Notification forms and additional rule information can be found on the following website:

<http://www.epa.gov/ttn/atw/boiler/boilerpg.html>.

a. Compliance Dates, Notifications, and Work Practice Requirements

i. Initial Notification of Compliance

An Initial Notification submittal to EPA was due no later than January 20, 2014 or for new sources - within 120 days after the source becomes subject to the standard. [40 CFR Part 63.11225(a)(2)]

ii. Boiler Tune-Up Program

(a) A boiler tune-up program shall be implemented. [40 CFR Part 63.11223]

(b) Each tune-up shall be conducted at a frequency specified by the rule and based on the size, age, and operations of the boiler. See chart below:

<b>Boiler Category</b>	<b>Tune-Up Frequency</b>
New or Existing Oil, Biomass and Coal fired boilers that are not designated as "Boilers with less frequent tune up requirements" listed below	Every 2 years
<i>New and Existing Oil, Biomass, and Coal fired Boilers with less frequent tune up requirements</i>	
Seasonal (see definition §63.11237)	Every 5 years
Limited use (see definition §63.11237)	Every 5 years
With a heat input capacity of <5MMBtu/hr	Every 5 years
Boiler with oxygen trim system which maintains an optimum air-to-fuel ratio that would otherwise be subject to a biennial tune up	Every 5 years

[40 CFR Part 63.11223(a) and Table 2]

(c) The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:

1. As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for oil fired boilers less than 5 MMBtu/hr, boilers with oxygen trim systems, seasonal boilers, and limited use boilers. [40 CFR Part 63.11223(b)(1)]
2. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 CFR Part 63.11223(b)(2)]
3. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for oil fired boilers less than 5 MMBtu/hr, boilers with oxygen trim systems, seasonal boilers, and limited use boilers. [40 CFR Part 63.11223(b)(3)]
4. Optimize total emissions of CO, consistent with manufacturer's specifications. [40 CFR Part 63.11223(b)(4)]
5. Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 CFR Part 63.11223(b)(5)]
6. If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 CFR Part 63.11223(b)(7)]

(d) Tune-Up Report: A tune-up report shall be maintained onsite and, if requested, submitted to EPA. The report shall contain the following information:

1. The concentration of CO in the effluent stream (ppmv) and oxygen (volume percent) measured at high fire or typical operating load both **before** and **after** the boiler tune-up;
2. A description of any corrective actions taken as part of the tune-up of the boiler; and
3. The types and amounts of fuels used over the 12 months prior to the tune-up of the boiler; but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.

[40 CFR §63.11223(b)(6)]

- (e) After conducting the initial boiler tune-up, a Notification of Compliance Status was to be submitted to EPA no later than July 19, 2014. [40 CFR Part 63.11225(a)(4) and 40 CFR Part 63.11214(b)]

iii. Compliance Report:

A compliance report shall be prepared by March 1<sup>st</sup> every five years which covers the previous five calendar years. The report shall be maintained by the source and submitted to the Department and to the EPA upon request. The report must include the items contained in §63.11225(b)(1) and (2), including the following:

[40 CFR §63.11225(b)]

- (a) Company name and address;
- (b) A statement of whether the source has complied with all the relevant requirements of this Subpart;
- (c) A statement certifying truth, accuracy, and completeness of the notification and signed by a responsible official and containing the official's name, title, phone number, email address, and signature;
- (d) The following certifications, as applicable:
  - i. "This facility complies with the requirements in 40 CFR §63.11223 to conduct tune-ups of each boiler in accordance with the frequency specified in this Subpart."
  - ii. "No secondary materials that are solid waste were combusted in any affected unit."
  - iii. "This facility complies with the requirement in 40 CFR §§63.11214(d) to conduct a tune-up of each applicable boiler according to 40 CFR §63.11223(b)."

b. Recordkeeping

Records shall be maintained consistent with the requirements of 40 CFR Part 63, Subpart JJJJJ including the following [40 CFR Part 63.11225(c)]:

- i. Copies of notifications and reports with supporting compliance documentation;
- ii. Identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned;
- iii. Records of the occurrence and duration of each malfunction of each applicable boiler; and
- iv. Records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore the malfunctioning boiler.

Records shall be in a form suitable and readily available for expeditious review.

D. Stock Piles and Roadways

Visible emissions from a fugitive emission source shall not exceed an opacity of 20%, except for no more than five (5) minutes in any 1-hour period. Compliance shall be determined by an aggregate of the individual fifteen (15)-second opacity observations which exceed 20% in any one (1) hour.

E. General Process Emissions

Visible emissions from any general process (including conveyor belts, transfer points, etc.) associated with an NSPS rock crusher shall not exceed an opacity of 7% on a six (6) minute block average basis.

Visible emissions from any other general process (non-NSPS crusher conveyor belts, bucket elevators, bagging operations, truck loading operations, etc.) shall not exceed an opacity of 20% opacity on a six (6)-minute block average basis except for no more than one (1), six (6)-minute block average in a one (1)-hour period.

F. Annual Emissions

1. Total Annual Emissions

Hissong shall be restricted to the following annual emissions, based on a calendar year. The tons per year limits were calculated based on a boiler fuel limit of 100,000 gallons per year of distillate fuel.

**Total Licensed Annual Emissions for the Facility**  
**Tons per year**  
(used to calculate the annual license fee)

	<u>PM</u>	<u>PM<sub>10</sub></u>	<u>SO<sub>2</sub></u>	<u>NO<sub>x</sub></u>	<u>CO</u>	<u>VOC</u>
Boiler #1	0.6	0.6	3.5	2.1	0.3	0.1
<b>Total TPY</b>	<b>0.6</b>	<b>0.6</b>	<b>3.5</b>	<b>2.1</b>	<b>0.3</b>	<b>0.1</b>

2. Greenhouse Gases

Greenhouse gases are considered regulated pollutants as of January 2, 2011, through 'Tailoring' revisions made to EPA's *Approval and Promulgation of Implementation Plans*, 40 CFR Part 52, Subpart A, §52.21, *Prevention of Significant Deterioration of Air Quality* rule. Greenhouse gases, as defined in 06-096 CMR 100 (as amended), are the aggregate group of the following gases: carbon dioxide, nitrous oxide, methane, hydrofluorocarbons, perfluorocarbons, and sulfur hexafluoride. For licensing purposes, greenhouse gases (GHG) are calculated and reported as carbon dioxide equivalents (CO<sub>2</sub>e).

The quantity of CO<sub>2</sub>e emissions from this facility is less than 100,000 tons per year, based on the following:

- the facility's fuel use limit;
- worst case emission factors from the following sources: U.S. EPA's AP-42, the Intergovernmental Panel on Climate Change (IPCC), and 40 CFR Part 98, *Mandatory Greenhouse Gas Reporting*; and
- global warming potentials contained in 40 CFR Part 98.

No additional licensing actions to address GHG emissions are required at this time.

### III. AMBIENT AIR QUALITY ANALYSIS

The level of ambient air quality impact modeling required for a minor source shall be determined by the Department on a case-by case basis. In accordance with 06-096 CMR 115, an ambient air quality impact analysis is not required for a minor source if the total licensed annual emissions of any pollutant released do not exceed the following levels and there are no extenuating circumstances:

<b>Pollutant</b>	<b>Tons/Year</b>
PM <sub>10</sub>	25
SO <sub>2</sub>	50
NO <sub>x</sub>	50
CO	250

The total licensed annual emissions for the facility are below the emission levels contained in the table above and there are no extenuating circumstances; therefore, an ambient air quality impact analysis is not required as part of this license.

### ORDER

Based on the above Findings and subject to conditions listed below the Department concludes that the emissions from this source:

- will receive Best Practical Treatment,
- will not violate applicable emission standards,
- will not violate applicable ambient air quality standards in conjunction with emissions from other sources.

The Department hereby grants Air Emission License A-1025-71-B-R, subject to the following conditions:

Severability. The invalidity or unenforceability of any provision, or part thereof, of this License shall not affect the remainder of the provision or any other provisions. This License shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted.

### STANDARD CONDITIONS

- (1) Employees and authorized representatives of the Department shall be allowed access to the licensee's premises during business hours, or any time during which any emissions units are in operation, and at such other times as the Department deems necessary for the purpose of performing tests, collecting samples, conducting inspections, or examining and copying records relating to emissions (38 M.R.S.A. §347-C).
- (2) The licensee shall acquire a new or amended air emission license prior to commencing construction of a modification, unless specifically provided for in Chapter 115. [06-096 CMR 115]
- (3) Approval to construct shall become invalid if the source has not commenced construction within eighteen (18) months after receipt of such approval or if construction is discontinued for a period of eighteen (18) months or more. The Department may extend this time period upon a satisfactory showing that an extension is justified, but may condition such extension upon a review of either the control technology analysis or the ambient air quality standards analysis, or both. [06-096 CMR 115]
- (4) The licensee shall establish and maintain a continuing program of best management practices for suppression of fugitive particulate matter during any period of construction, reconstruction, or operation which may result in fugitive dust, and shall submit a description of the program to the Department upon request. [06-096 CMR 115]
- (5) The licensee shall pay the annual air emission license fee to the Department, calculated pursuant to Title 38 M.R.S.A. §353-A. [06-096 CMR 115]
- (6) The license does not convey any property rights of any sort, or any exclusive privilege. [06-096 CMR 115]
- (7) The licensee shall maintain and operate all emission units and air pollution systems required by the air emission license in a manner consistent with good air pollution control practice for minimizing emissions. [06-096 CMR 115]
- (8) The licensee shall maintain sufficient records to accurately document compliance with emission standards and license conditions and shall maintain such records for a minimum of six (6) years. The records shall be submitted to the Department upon written request. [06-096 CMR 115]

- (9) The licensee shall comply with all terms and conditions of the air emission license. The filing of an appeal by the licensee, the notification of planned changes or anticipated noncompliance by the licensee, or the filing of an application by the licensee for a renewal of a license or amendment shall not stay any condition of the license. [06-096 CMR 115]
- (10) The licensee may not use as a defense in an enforcement action that the disruption, cessation, or reduction of licensed operations would have been necessary in order to maintain compliance with the conditions of the air emission license. [06-096 CMR 115]
- (11) In accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department, the licensee shall:
- A. perform stack testing to demonstrate compliance with the applicable emission standards under circumstances representative of the facility's normal process and operating conditions:
    - 1. within sixty (60) calendar days of receipt of a notification to test from the Department or EPA, if visible emissions, equipment operating parameters, staff inspection, air monitoring or other cause indicate to the Department that equipment may be operating out of compliance with emission standards or license conditions; or
    - 2. pursuant to any other requirement of this license to perform stack testing.
  - B. install or make provisions to install test ports that meet the criteria of 40 CFR Part 60, Appendix A, and test platforms, if necessary, and other accommodations necessary to allow emission testing; and
  - C. submit a written report to the Department within thirty (30) days from date of test completion.
- [06-096 CMR 115]
- (12) If the results of a stack test performed under circumstances representative of the facility's normal process and operating conditions indicate emissions in excess of the applicable standards, then:
- A. within thirty (30) days following receipt of such test results, the licensee shall re-test the non-complying emission source under circumstances representative of the facility's normal process and operating conditions and in accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department; and

- B. the days of violation shall be presumed to include the date of stack test and each and every day of operation thereafter until compliance is demonstrated under normal and representative process and operating conditions, except to the extent that the facility can prove to the satisfaction of the Department that there were intervening days during which no violation occurred or that the violation was not continuing in nature; and
- C. the licensee may, upon the approval of the Department following the successful demonstration of compliance at alternative load conditions, operate under such alternative load conditions on an interim basis prior to a demonstration of compliance under normal and representative process and operating conditions.

[06-096 CMR 115]

- (13) Notwithstanding any other provisions in the State Implementation Plan approved by the EPA or Section 114(a) of the CAA, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any statute, regulation, or Part 70 license requirement. [06-096 CMR 115]
- (14) The licensee shall maintain records of malfunctions, failures, downtime, and any other similar change in operation of air pollution control systems or the emissions unit itself that would affect emissions and that is not consistent with the terms and conditions of the air emission license. The licensee shall notify the Department within two (2) days or the next state working day, whichever is later, of such occasions where such changes result in an increase of emissions. The licensee shall report all excess emissions in the units of the applicable emission limitation. [06-096 CMR 115]
- (15) Upon written request from the Department, the licensee shall establish and maintain such records, make such reports, install, use and maintain such monitoring equipment, sample such emissions (in accordance with such methods, at such locations, at such intervals, and in such a manner as the Department shall prescribe), and provide other information as the Department may reasonably require to determine the licensee's compliance status. [06-096 CMR 115]

#### **SPECIFIC CONDITIONS**

##### **(16) Concrete Batch Plant**

- A. Particulate emissions from each of the cement silos shall be vented through a baghouse and all components of the concrete batch plant shall be maintained so as to prevent PM leaks. [06-096 CMR 115, BPT]

- B. To document maintenance of the cement silo dust collection unit, the licensee shall keep a maintenance log recording the date and location of all bag failures as well as all routine maintenance. The maintenance log shall be kept on-site at the concrete batch plant location. [06-096 CMR 115, BPT]
  - C. Opacity from the cement silo dust collection unit is limited to no greater than 10% on a six (6)-minute block average basis, except for no more than one (1), six (6)-minute block average in a one (1)-hour period. Hissiong shall take corrective action if visible emissions from the dust collection unit exceed 5% opacity. [06-096 CMR 101]
  - D. PM emissions from the concrete batching operation shall be controlled so as to prevent visible emissions in excess of 20% opacity on a six (6) -minute block average basis, except for no more than one (1), six (6)-minute block average in a one (1)-hour period. [06-096 CMR 101]
- (17) **Boiler #1**
- A. Fuel
    - 1. Total fuel use for Boiler #1 shall not exceed 100,000 gallons per year of distillate fuel, based on a calendar year basis. [06-096 CMR 115, BPT]
    - 2. Prior to July 1, 2016 or the date specified in 38 MRSA §603-A(2)(A)(3), the distillate fuel fired in the boiler shall have a maximum sulfur content of 0.5% by weight. [06-096 CMR 115, BPT]
    - 3. Beginning July 1, 2016 or on the date specified in 38 MRSA §603-A(2)(A)(3), the facility shall fire distillate fuel with a maximum sulfur content limit of 0.005% by weight (50 ppm). [38 MRSA §603-A(2)(A)(3)]
    - 4. Beginning January 1, 2018 or on the date specified in 38 MRSA §603-A(2)(A)(3), the facility shall fire distillate fuel with a maximum sulfur content limit of 0.0015% by weight (15 ppm). [38 MRSA §603-A(2)(A)(3)]
    - 5. Compliance shall be demonstrated by fuel records from the supplier showing the quantity, type, and the percent sulfur of the fuel delivered (if applicable). Records of annual fuel use shall be kept on a monthly and calendar year basis. [06-096 CMR 115, BPT]

B. Emissions shall not exceed the following [06-096 CMR 115, BPT]:

<u>Emission Unit</u>	<u>PM</u> (lb/hr)	<u>PM<sub>10</sub></u> (lb/hr)	<u>SO<sub>2</sub></u> (lb/hr)	<u>NO<sub>x</sub></u> (lb/hr)	<u>CO</u> (lb/hr)	<u>VOC</u> (lb/hr)
Boiler #1	0.22	0.22	1.41	0.84	0.10	0.01

C. Visible emissions from Boiler #1 shall not exceed 20% opacity on a six (6)-minute block average, except for no more than one (1), six (6)-minute block averages in a continuous three (3)-hour period. [06-096 CMR 101]

D. Boiler MACT (40 CFR Part 63, Subpart JJJJJ) Requirements for Boiler #1 [incorporated under 06-096 CMR 115, BPT]

1. An Initial Notification submittal to EPA was due within 120 days after the source becomes subject to the standard. [40 CFR Part 63.11225(a)(2)]
2. The facility shall implement a boiler tune-up program. [40 CFR Part 63.11223]
  - (a) Each tune-up shall be conducted at a frequency specified by the rule and based on the size, age, and operations of the boiler. See chart below:

<u>Boiler Category</u>	<u>Tune-Up Frequency</u>
New or Existing Oil, Biomass and Coal fired boilers that are not designated as "Boilers with less frequent tune up requirements" listed below	Every 2 years
<i>New and Existing Oil, Biomass, and Coal fired Boilers with less frequent tune up requirements</i>	
Seasonal (see definition §63.11237)	Every 5 years
Limited use (see definition §63.11237)	Every 5 years
With a heat input capacity of < 5MMBtu/hr	Every 5 years
Boiler with oxygen trim system which maintains an optimum air-to-fuel ratio that would otherwise be subject to a biennial tune up	Every 5 years

[40 CFR Part 63.11223(a) and Table 2]

- (b) The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:
- (1) As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for oil fired boilers less than 5 MMBtu/hr, boilers with oxygen trim systems, seasonal boilers, and limited use boilers. [40 CFR Part 63.11223(b)(1)]
  - (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 CFR Part 63.11223(b)(2)]
  - (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for oil fired boilers less than 5 MMBtu/hr, boilers with oxygen trim systems, seasonal boilers, and limited use boilers. [40 CFR Part 63.11223(b)(3)]
  - (4) Optimize total emissions of CO, consistent with manufacturer's specifications. [40 CFR Part 63.11223(b)(4)]
  - (5) Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 CFR Part 63.11223(b)(5)]
  - (6) If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 CFR Part 63.11223(b)(7)]
- (c) Tune-Up Report: A tune-up report shall be maintained onsite and, if requested, submitted to EPA. The report shall contain the following information:
- (1) The concentration of CO in the effluent stream (ppmv) and oxygen (volume percent) measured at high fire or typical operating load both **before** and **after** the boiler tune-up;
  - (2) A description of any corrective actions taken as part of the tune-up of the boiler; and

(3) The types and amounts of fuels used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.

[40 CFR §63.11223(b)(6)]

(d) After conducting the initial boiler tune-up, a Notification of Compliance Status was to be submitted to EPA no later than July 19, 2014. [40 CFR Part 63.11225(a)(4) and 40 CFR Part 63.11214(b)]

3. Compliance Report:

A compliance report shall be prepared by March 1<sup>st</sup> every five years which covers the previous five calendar years. The report shall be maintained by the source and submitted to the Department and to the EPA upon request. The report must include the items contained in §63.11225(b)(1) and (2), including the following: [40 CFR §63.11225(b)]

- (a) Company name and address;
- (b) A statement of whether the source has complied with all the relevant requirements of this Subpart;
- (c) A statement certifying truth, accuracy, and completeness of the notification and signed by a responsible official and containing the official's name, title, phone number, email address, and signature;
- (d) The following certifications, as applicable:
  - (1) "This facility complies with the requirements in 40 CFR §63.11223 to conduct tune-ups of each boiler in accordance with the frequency specified in this Subpart."
  - (2) "No secondary materials that are solid waste were combusted in any affected unit."
  - (3) "This facility complies with the requirement in 40 CFR §§63.11214(d) to conduct a tune-up of each applicable boiler according to 40 CFR §63.11223(b)."

(18) **Stockpiles and Roadways**

Visible emissions from a fugitive emission source shall not exceed 20% opacity, except for no more than five (5) minutes in any one (1)-hour period. Compliance shall be determined by an aggregate of the individual fifteen (15)-second opacity observations which exceed 20% in any one (1) hour. [06-096 CMR 101]

(19) **General Process Sources**

Visible emissions from any other general process (non-NSPS crusher conveyor belts, bucket elevators, bagging operations, truck loading operations, etc.) shall not exceed 20% opacity on a six (6)-minute block average basis except for no more than one (1), six (6)-minute block average in a one (1)-hour period. [06-096 CMR 115, BPT]

(20) **Equipment Relocation** [06-096 CMR 115, BPT]

A. Hissong shall notify the Bureau of Air Quality, by a written notification, prior to relocation of any equipment carried on this license. It is preferred for notice of relocation to be submitted through the Department's on-line e-notice at: [www.maine.gov/dep/air/compliance/forms/relocation](http://www.maine.gov/dep/air/compliance/forms/relocation)

Written notice may also be sent by fax (207-287-7641) or mail. Notification sent by mail shall be sent to the address below:

Attn: Relocation Notice  
Maine DEP  
Bureau of Air Quality  
17 State House Station  
Augusta, ME 04333-0017

The notification shall include the address of the equipment's new location, an identification of the equipment and the license number pertaining to the relocated equipment.

B. Written notification shall also be made to the municipality where the equipment will be relocated, except in the case of an unorganized territory where notification shall be made to the respective county commissioners.

Hissong Ready-Mix & Aggregates, LLC  
York County  
Eliot, Maine  
A-1025-71-B-R

19

Departmental  
Findings of Fact and Order  
Air Emission License  
Renewal

- (21) Hissong shall keep a copy of this Order on site, and have the operator(s) be familiar with the terms of this Order. [06-096 CMR 115, BPT]
- (22) Hissong shall notify the Department within 48 hours and submit a report to the Department on a quarterly basis if a malfunction or breakdown in any component causes a violation of any emission standard [38 M.R.S.A. §605].

DONE AND DATED IN AUGUSTA, MAINE THIS 22 DAY OF May, 2015.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY: Marc Allen Robert Cone for  
PATRICIA W. AHO, COMMISSIONER

**The term of this license shall be ten (10) years from the signature date above.**

[Note: If a complete renewal application, as determined by the Department, is submitted prior to expiration of this license, then pursuant to Title 5 MRSA §10002, all terms and conditions of the license shall remain in effect until the Department takes final action on the renewal of the license.]

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application: 02/20/2015  
Date of application acceptance: 03/05/2015

Date filed with the Board of Environmental Protection:

This Order prepared by N. Lynn Cornfield, PE, Bureau of Air Quality.

