



# Tank Interstitial Manual Monitoring Log for Double-walled Systems



\_\_\_\_\_  
Facility Name

\_\_\_\_\_  
Registration number

\_\_\_\_\_  
Address

\_\_\_\_\_  
Tank ID # and Product

DATE	FUEL?	WATER?	PERSON SAMPLING

**Instructions:** Use a separate sheet for each tank. Check weekly. Always use a clean stick, not one that has been used to measure fuel levels. At the bottom 1”-2” of the stick, smear a small amount of gas paste on one side and a small amount of water paste on the other side. Lower the stick to the bottom of the interstitial sump, pause for a few seconds and raise it back up. If either paste has turned color, clean the stick and repeat the procedure. If either the gas paste or the water paste has again turned color, promptly notify the Department of Environmental Protection by calling (207) 287-7688 during normal business hours or 1-800-482-0777 after normal business hours. If the paste did not change color, record the date, enter “None” in the fuel and water columns and put your initials or name in the right-hand column.

***Keep this completed form on site for three (3) years.***