| Surface Water Treatment Rule System Type - SW and GUI unfiltered systems | | | | | | System | Intormat Treatment | : ion) plant/pump station: | | |
|--|--------------|------------|-------------------|-----------|--|--|--|---|--------------------|--|
| , | • | se Chlo | | | | | | ,, . , | | |
| System Name: | | | | | Total Chlorine Residual in the distribution system | | | | | |
| | PWSID#: | | | | | a = | | # of samples w/C½ resid | dual | |
| Demonstration and | | | | | | b = # of samples where C½ is not meas. but HPC's are | | | | |
| Reporting period: | | | | | c = # of samples with Cb not detected & HPC < 500 | | | | | |
| Cian atura. | | | Date: | | | d = # of samples with Cb not detected & HPC > 500/mL | | | | |
| Signature: | | | Date | | | e = | e = # of samples where C½ is not meas. & HPC | | | |
| Free Chlorine Residual at Entry Poin | | | nt (lowest value) | | V= (c+d+ | , X 100 \ | current month V = / for previous month = | | | |
| Date | Daily min. | Date | Daily min. | Date | Daily min. | (a+b | | V > 5% for 2 months? | □No | Yes |
| 4 | mg/L | 40 | mg/L | 00 | mg/L | | | Source Water Col | iform | |
| 1 | | 12 | | 23 | | | ٠ | lation acceptant and accepts | | |
| 3 | | 13 14 | | 24 | | | | lative number of months | Fecal | ☐ Total |
| 4 | | 15 | | 25 26 | | | | Coliform sampling type: | | Пота |
| 5 | | 16 | | 27 | | | | form samples taken in th = 20/100 mL fecal or <= | | |
| 6 | | 17 | | 28 | | Numbe | oi sampies <= | | ge meeting limit: | |
| 7 | | 18 | | 29 | | | | Is this < 90%? | No | Yes |
| 8 | | 19 | | 30 | | | | | | |
| 9 | | 20 | | 31 | | | l | Source Water Tur | bidity | |
| 10 | | 21 | | <u> </u> | <u>I</u> | | | Maximum turbidity for th | ne current month: | |
| 11 | | 22 | | 1 | | Turbidit | / > 5 NTU ovei | the past 120 months | Turbidity > 1 NTL | I this month |
| | Co | ntinuous N | Monitoring? | ☐ No | Yes | Date | Value | Date reported | Date | Value |
| If no, enter the # of free chlorine | | | | | • | | | | | |
| | residual mea | asurement | s for month: | | | | | | | |
| Cont | act the DW | P withi | n 24 hour | s at 287- | 2070 | | | | | |
| (afterhour | s pager 55 | 7-4214) | if your sy | stem fai | ils to meet | | | | | |
| d | isinfection | or turb | idity requ | irements | S. | | | | | |
| Inactivation Ratios | | | Dis. | peak flow | Disinfectant | CT _{calc} | рН | Water Temp. | CT _{99.9} | CT _{calc} /CT _{99.9} |
| for Giardia for | | Date | Conc."C" | (gpm) | contact time | (=CxT) | (chlorine only) | | (calculated using | |
| systems using | | 1 | (mg/L) | | "T" (min) | | | | equation) | ratio |
| Chlorine | | 2 | | | | | | | | |
| <u> </u> | 211119 | 3 4 | | | | | | | | |
| | | 5 | | | | | | | | |
| | | 6 | | | | | | | | |
| Are any inactivation ratios | | 7 8 | | | | | | | | |
| $(CT_{calo}/CT_{99.9}) < 1.0?$ | | 9 | | | | | | | | |
| ☐ No | Yes | 10 | | | | | | | | |
| | | 11 12 | | | | | | | | |
| | | 13 | | | | | | | | |
| | | 14 | | | | | | | | |
| | | 15 16 | | | | | | | | |
| | | 17 | | | | | | | | |
| | | 18 | | | | | | | | |
| | | 19 20 | | | | | | | | |
| | | 21 | | | | | | | | |
| | | 22 | | | | | | | | |
| | | 23 24 | | <u> </u> | | | | | | |
| | | 24 25 | | | | | | | 1 | |
| | | 26 | | | | | | | | |
| | | 27 28 | | | | | | | | |
| | | 29 | | | | | | | | |
| | | 30 | <u></u> | | | | | | | |
| | | 31 | | | | | | | | |