

Well Driller's Meeting
Date: Wednesday, October 21, 2015
Location: 286 Water Street, 1st Floor

Attendees: Commission Members:
Dwight Doughty, Jr. Hydrogeologist, Maine DOT
Ryan Gordon, Hydrogeologist, Maine Geological Survey
Mike Otley, Public Member
Ike Goodwin, Master Driller
Frank Hegarty, Master Pump Installer
Julia Kimball, Commission Clerk
Legal Counsel: Deanna White, AAG

Minutes prepared by: Julia Kimball

PROCEEDINGS:

Dwight Doughty - Meeting called to order at 9:00 a.m.

TOPIC: August 2015 Meeting

Motion: Ike motioned to approve the August minutes (no September meeting). Mike 2nd.

Discussion – None

Vote: Unanimous to approve.

TOPIC: Licensure Application

An application for a Master Pump Installer license was discussed. Thomas Ogden is a licensed driller in New Hampshire and Massachusetts. Mr. Ogden did not provide any references and therefor his application is incomplete.

Motion: Frank motioned to deny Thomas Ogden's Master Pump Installer application. Ike 2nd.

Vote: Unanimous to deny.

TOPIC: Specialty Well Applications

An application was brought before the Commission located at 62 Berry Rd, Sweden, ME. The reason for the application was for lack of space on property. The leachfield setback is 25 ft and tank setback is 38 ft. The well is approved with 120 feet of casing, a 10 inch hole grouted bottom to top.

Motion: Ike motioned to accept the application. Frank 2nd.

Vote: Unanimous to approve

TOPIC: Other Business

The Commission continued discussions of the meetings with the Plumber's Examining Board.

TOPIC: Complaints:

None Pending

9:50: Frank motioned to adjourn, 2nd by Ike, approved unanimously

Next Meeting: November 10, 2015 286 Water Street, Augusta, Maine 9:00 A.M.