



JOHN ELIAS BALDACCI  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE  
04333-0016

December 26, 2008  
Subject: **Fort Kent**  
Project No. STP-1000(210)X  
State Pin Nos. 010002.10  
**Amendment No. 1**

DAVID A. COLE  
COMMISSIONER

Dear Sir/Ms:

The following questions have been received:

**Question:** Please verify the material needed for item 304.20 – Cold In-Place Recycling Shimming Aggr.. Does the aggregate need to be crushed or not. Please advise.

**Response:** The material used for the shimming aggregate can be crushed or un-crushed as long as it meets the gradation of Item 411.10 as requested.

Refer to SPECIAL PROVISION, SECTION 308, FULL DEPTH RECYCLING WITH CEMENT, (page 60), section 308.021 New Aggregate and Additional Recycled Material.

**Question:** For Cross Trenches completed on mainline that are compacted, what material is needed or allowed to be placed for temporary trench covers until foaming is complete

**Response:** The material used in the cross pipe trenches, prior to cold in place operation needs to be either HMA or crushed pavement millings caped with an acceptable HMA that will support traffic.

Consider this information prior to submitting your bid on **January 7, 2009**.

Sincerely,

Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER