

STATE OF MAINE DEPARTMENT OF TRANSPORTATION 16 STATE HOUSE STATION AUGUSTA, MAINE 04333-0016

May 2, 2008 Subject: **Fryeburg** Project No. BR-1264(900)X, BH-1560(400)X Pin No.012649.00, 015604.00 **Amendment No. 1** DAVID A. COLE

COMMISSIONER

Dear Sir/Ms:

The following question has been received:

Question: Reference the Schedule of Items, item 520.2401, Bridge Joint Modification Type 1. Could you please identify the size of the expansion joints needed for these projects?

Response: These movement ratings are for bidding purposes only:

Walkers Bridge Abutment 1 - movement rating 1 ½"

Abutment 2 - movement rating 1 ½"

Osgood Bridge – movement rating 2 1/8"

The Contractor will need to measure the bridge joint openings and deck temperature, and then get approval from the Resident before ordering/fabricating the seals.

Consider this information prior to submitting your bid on May 7, 2008.

Sincerely,

Scott Bickford

Contracts & Specifications Engineer

