



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

August 31, 2009
Subject: **Standish**
State Pin No: 012698.00
Amendment No. 2

Dear Sir/Ms:

Make the following change to the Bid Document:

In the Bid Book (page 33), **REMOVE** "SPECIAL PROVISION, SECTION 105, GENERAL SCOPE OF WORK", 1 page undated and **REPLACE** with the attached new "SPECIAL PROVISION, SECTION 105, GENERAL SCOPE OF WORK", 1 page undated.

The following questions have been received:

Question: Can you provide any water flow information on Tucker Brook, what's the average flow level in the pipe? Will a coffer dam be required?

Response: Low flow is on account of an upstream beaver dam. Water depth is generally 9-18". MDOT will install cofferdams.

Question: Please let me know if this is the correct sequence of events. Our bid should include surface preparation and installation of the machine bolts or studs, but the Department will install the rebar that connects to the bolts or studs?

Response: MDOT will install studs to hang the rebar. If the successful Contractor requires additional studs it will be the Contractor's responsibility to supply and install them. MDOT also scales loose corrosion from the culvert. If further cleaning is required by the Contractor before spot painting it is the Contractor's responsibility to do this work.

Consider this change and information prior to submitting your bid on September 2, 2009.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER

Standush
12698.00
Shotcrete

SPECIAL PROVISION
SECTION 105
GENERAL SCOPE OF WORK

The contract lump sum price shall be full compensation for the structural concrete invert lining which shall include mobilization, the application by pneumatic pressure of a shotcrete mix, application of asphalt emulsion, clean up and demobilization and furnishing all materials, equipment, labor, and incidentals necessary to complete the work. Shotcrete shall be placed to line and grades shown on plans.

The Department will provide traffic control.

The Department will install bolts or studs and rebar.

The Department will provide soil erosion and water pollution control.