



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

October 15, 2007
Subject: **Standish - Fryeburg**
Project No. N/A
Pin No's 014462.10 & 014463.10
Amendment No. 1

Dear Sir/Ms:

The following question has been received.

Question: The specifications call out a 92% density on the pavement, is there a way to waive this requirement?

Response: No

Consider this information prior to submitting your bid on October 17, 2007.

Sincerely,

A handwritten signature in black ink, appearing to read "S. Bickford" with "FOR" written to the right.

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER