



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI

GOVERNOR

DAVID A. COLE

COMMISSIONER

July 21, 2008
Subject: **Lincolntonville, Islesboro**
Federal Project No. BR-1561(500)X,
BR-1561(600)X
State Pin No. 015615.00, 015616.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Regarding the 5" Heavy Duty Grating for the Transfer Spans, Note 4 on Sheet 19 of 37 states that the material is to be A588. Is there a specific finish required (galvanized or paint) or is it mill finish?

Response: The grating is to be hot-dip galvanized. See note 12 on Sheet 19 of 37 as well as Special Provision – Technical Section 531 – Transfer Bridge, Hoist Machinery and Hoist Tower on page 531-1.

Consider this information prior to submitting your bid on **July 23, 2008**.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER