



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

July 2, 2008
Subject: **Appleton**
State Pin No.012683.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Would you consider the use of Polymer Coated CMP for this project? RCP and Polymer Coated CMP carry a design life of 100 years +/-.

Response: No

Consider this information prior to submitting your bid on **July 9, 2008.**

Sincerely,

A handwritten signature in black ink, appearing to read "S. Bickford FOR".

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER