



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

October 7, 2011
Subject: **Orrington**
Federal Project No: STP-9204(100)X
State PIN: 009204.10
Amendment No. 2

Dear Sir/Ms:


The following question has been received:

Question: General Note #50 on sheet 11 of 208 states that shape 5 (offset cone) and flat top catch basins are not to be used unless noted on the plans. We would like to request that offset cones be allowed for this project since a straight cone does not allow any flexibility in the placement of the frame and cover.

Response: Shape #1 is the required shape for B1-C Catch Basins. The Resident may authorize Shape #5 to accommodate existing field conditions.

Consider this information prior to submitting your bid on October 12, 2011.

Sincerely,


for Scott Bickford

Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER