



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

April 26, 2011
Subject: **Portland**
Federal Project No: IM-1792(900)E
State Pin No: 017929.00
Amendment No. 3

Dear Sir/Ms:

The following question has been received:

Question: Does the Repair and Replace Glare Foil item require a base rail?

Response: No. The existing glare foils installed from Tukeys Bridge to Kensington Street Overpass Bridge has no base rail, individual glare foils blade bases attach directly to the median barrier. Work shall include repair and replacement of glare foil blades, blade bases and associated hardware as directed by the Resident.

Consider this information prior to submitting your bid on April 27, 2011.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER