



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

April 18, 2013
Subject: **Rockport & Hope**
Federal Project No: Nh-1829(900)E
& AC-STP-1913(200)X
State WIN: 018299.00 & 019132.00
Amendment No. 1

David Bernhardt
COMMISSIONER

Dear Sir/Ms:

The following questions have been received:

Question: Item 606.358, is the post spacing already 6' 3" or is it 12' 6". Need to know if post is needed in modification?

Response: Post spacing of existing guardrail is 6'-3".

Question: What are the existing end treatments?

Response: The existing end treatments are BCT's and are to be replaced with Item 606.79 Guardrail Flared 350 Terminals as per the Construction Notes. The removed BCT's or unusable guardrail will become the property of the Contractor.

Consider this information prior to submitting your bid on April 24, 2013.

Sincerely,



for
George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON 100% RECYCLED PAPER