



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

April 5, 2013
Subject: **Calais**
Federal Project No: NH-1830(300)X &
AC-IB-1921(700)X
State WIN: 018303.00 & 019217.00
Amendment No. 1

David Bernhardt
COMMISSIONER

Dear Sir/Ms:

The following question has been received:

Question: Is there existing guardrail to be removed? If so, what type?

Response: Approximately 14000' of Type 3B guardrail will need to be removed from this project and will become the property of the Department as per General Note #19.

Consider this information prior to submitting your bid on April 17, 2013.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER