



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

March 25, 2013

Subject: **Belgrade, Oakland and
Smithfield**

Federal Project No: STP-1830(900)X &
STP-1831(000)X

State WIN: 018309.00 & 018310.00

Amendment No. 3

David Bernhardt
COMMISSIONER

Dear Sir/Ms:

The following question has been received:

Question: Please confirm the locations of the items per the contract are correct. I visited the site yesterday and was unable to find the existing structure to be adjusted in item 604.18 and the existing structure to be removed under item 604.092. I also will need to know the size and diameters of existing pipes to be connected to the new catch basin to be installed in item 604.092. Please confirm if the attached sketch is the correct interpretation of the items to be installed and is there one or two existing structures to be removed at the location of the new catch basin to be installed?

Response: As the notes indicate on page 1 of 3 in the Construction Notes, the removal of the old structure and the installation of the new catch basin is at station 20+50 RT, which is in close proximity to Pleasant St. The Contractor is responsible to verify pipe sizes prior to ordering the new catch basin.

Consider this information prior to submitting your bid on March 27, 2013.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER