



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

May 31, 2013
Subject: **Corinna & Exeter**
Federal Project No: STP-1831(600)X
State WIN: 018316.00
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: On page 45 of the Specifications, the Wage Rates for the Grader/Blade, Milling Machine are: Rate \$26.21, Fringe \$23.64. Is the fringe correct?

Response: The wage rates published in the Specifications are prescribed by the Department of Labor, the wage rates are as stated in the book.

Question: The entrance to the Grant pit is located at 189 Exeter Road has a bridge running across the road. The Contractor will need to bring Equipment into the pit for the crushing operation that will weigh in excess of 115,000 lbs., will the Bridge handle this weight?

Response: A representative of the Department has conducted a review of the bridge and it appears to be structurally capable of handling these loads. However, the Contractor shall use caution in crossing the structure and is responsible for the maintenance of the structure.

Consider this information prior to submitting your bid on June 5, 2013.

Sincerely,


for George M. A. Macdougall P.E.
Contracts & Specifications Engineer

PRINTED ON RECYCLED PAPER