STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

October 28, 2013
Subject: **Rockland**
Federal Project No: FBD-1834(210)
State WIN: 018342.10
Amendment No. 3

Dear Sir/Ms:

Please see below for the corrected response to question #8 of the "QUESTIONS AND ANSWERS FROM PRE-BID MEETING";

Question No. 8: Do the outside disconnects have to be stainless steel enclosures?

Response: ~~Surface-mounted wiring located in finished spaces shall be in Wiremold, or equal, raceway. Concealed wiring shall be MC cable or EMT (finished Attic spaces).~~

Corrected Response: **Exterior disconnect switches shall have a NEMA 3R enclosure.**

Consider this information prior to submitting your bid on **October 30**, 2013.

Sincerely,

for George M. A. Macdougall P.E.
Contracts & Specifications Engineer