



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

February 20, 2013
Subject: **Augusta**
Federal Project No: AC-STP-1901(100)X
State WIN: 019011.00
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Item 720.12 – Wood Sign Posts – Can these 4' x 4' posts be regular pressure treated wood?

Response: Yes. The 4" x 4" wood sign posts must be pressure treated.

Question: Item 720.08 – U-Channel Posts – What is the lb/lf requirement for the galvanized U-Channel posts? What is/are “rib back” U-Channel posts?

Response: The U-Channel posts shall weigh 2.5lb/ft. The “rib back” is a type of U-Channel that provides more strength and wind load capacity than conventional U-Channel posts.

Consider this information prior to submitting your bid on February 27, 2013.

Sincerely,

George M. A. Macdougall R.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER