



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

April 12, 2013
Subject: **Limington, Cornish &
Parsonfield**
Federal Project No: AC-STP-1907(900)X &
AC-STP-1909(000)X
State WIN: 019079.00 & 019090.00
Amendment No. 2

Dear Sir/Ms:


The following question has been received:

Question: The quantity for item 403.209 is significantly higher than our takeoff quantity. Where is the location of the bid quantity?

Response: The Department has reviewed their computations for the 403.209 item and has determined that it is an accurate representation of the amount required. Most paved driveways will go to the back of sidewalk; there is a 500'+/- section of sidewalk paving, and many field entrances that will receive a 3' lip.

Consider this information prior to submitting your bid on April 17, 2013.

Sincerely,


George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER