STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

January 31, 2013
Subject: **Belgrade**
State WIN: 019265.00
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: How will the Type III barricades shown on sheet 9 of the plans be paid for?

Response: The type III barricades will be considered incidental to the contract.

Question: What is the new 60" RCP to be bedded on?

Response: The new 60" RCP pipe shall be bedded on granular borrow; see page 3 notes 2 & 3.

Question: Could the road close for 6 days instead of 3 as mentioned on page 33 of the bid book? Are there penalties for doing so?

Response: No, a 3 day closure will only be allowed.

Consider this information prior to submitting your bid on February 13, 2013.

Sincerely,

for George M. A. Macdougall P.E.
Contracts & Specifications Engineer

PRINTED ON RECYCLED PAPER