



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

July 26, 2013
Subject: **Salt Building**
State WIN: 19850.00
Location: Edgecomb
Amendment No. 2

Dear Sir/Ms:

The following question has been received:

Question: I see your plans call for a 64' span x 64' long building. Would the state consider a proposal for 60' span arches?

Response: Please see **Plan Sheet # 3, (Foundation Plan)**, the outside dimensions for the building's concrete walls where the arches will set are 60' x 60'. The buildings footings outside dimension are 64' x 64'. This should accommodate the 60' span arches.

Consider this information prior to submitting your bid on July 31, 2013.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER