

**Addendum No. 2  
Town Landing Expansion  
Harrington, Maine**

**June 25, 2013**

**MDOT WIN 018391.10**

1. **RFI** - A Request for Information is included with this addendum. The response to the RFI is to be incorporated in the Construction Documents where applicable.

**PINE TREE  
ENGINEERING**

State of Maine  
Department of Transportation

**REQUEST FOR INFORMATION**

Date June 24, 2013 Time 10:00 a.m.

---

**Information Requested:** PIN: 018391.10 Town(s): Harrington

---

The existing concrete curbing, which consists of the old-style precast planks, is to be re-set next to the new launch ramp. Can the two additional curb sections be reused launch planks, or will they need to be precast concrete curbing?

---

---

---

---

---

---

---

---

---

---

---

**Request by:** Hanscom Construction **Bid Date:** June 27, 2013  
**Phone:** (        ) 255-8067 **Fax:** (        ) 255-6059

---

**Complete top portion of form and transmit to the number listed in the Notice to Contractors**

**RFI No:** 3 **RFI received:** June 24, 2013

**Response:** \_\_\_\_\_

The two additional curbs at the end of the launch ramp are to be new precast concrete curbs, in accordance with Section 609 of the specifications.

---

---

---

---

---

---

---

---

---

---

Response By: Jonathan C. DeWick, P.E. Date: June 24, 2013