

March 28, 2013
SHIP Project: 018391.11
Pilings and Whaler Rehabilitation
Amendment No. 1

Dear Sir/Ms:

Make the following changes(s) to the Bid Documents:

Changes:

In the Request for Bids "Pier Whalers and Pilings"

Delete the sentence:

Whalers are to be 12" X 12" X 20' 2.5 CCA Marine Treated White Pine.

Replace with

Whalers are to be 12" X 12" X 20' 2.5 CCA Marine Treated Southern Yellow Pine.

Regards,

John

Questions and Answers:

Question: Do the Pilings need to be driven?

Response: No, they are not load bearing pilings, the rest on the ocean floor.

Question: What is the capacity of the existing Pier?

Response: The pilings are fender pilings and not load bearing. As far as weight capacity for the pier, a truck weighing twenty tons can go out on the pier with no issues.

Question: What is the time frame for this project?

Response: Ideally we would like to have the project completed by Memorial Day, but we understand that that probably will not happen. We are willing to work with the selected contractor.

