



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

February 11, 2013
Subject: **On Call Electrical Services**
Location: **Region 4**
State Pin No: **N/A**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Are you requiring a specific height for the aerial lift?

Response: No, just sufficient to cover the Scope and Specifications of Work to be Performed stated in Appendix A, paragraph a. with a maximum height of 45 feet.

Consider this change and information prior to submitting your bid on February 20, 2013.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER