



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

August 12, 2013
Subject: **Culvert Replacement**
Location: **Leeds,
Monmouth & Greene**
Amendment No. 3

Dear Sir/Ms:

The following questions have been received:

Question: Any Rip-Rap at culvert end or slopes?

Response: No Rip rap is needed.

Question: Are slopes to be loamed and seeded?

Response: Use existing material that will support growth of grass, seeds. Mulch by hand.

Consider this information prior to submitting your bid on August 14, 2013.

Sincerely,

For George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER