



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

April 11, 2014
Subject: **Islesboro Crew Quarters**
Federal Project No: 018407.00
State 018407.00
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: Who supplies and installs the battery operated smoke detectors shown on drawing #3?

Response: The Contractor will be responsible for supplying and the installation of these smoke detectors as indicated.

Question: Can a specification for smoke detectors acquired be issued?

Response: When the project is awarded the Contractor will be responsible for submitting material submittals for the products to be used at which time the Project Manager and or Resident will make a determination as to the acceptance of the mentioned product.

Question: Division 09 – Finishes: Are there any interior finishes within the new addition? There is no Room Finish Schedule.

Response: Please review in the Bid Book (page 114 to 116) “Special Provision, Section 09900, Painting” page 1 to 3.

Question: Division 12 – Furnishings: Is there any multiple seating such as pews or benches? None are shown on the drawings.

Response: There are no multiple seating's in this project.

Question: Division No. 32 – Exterior Improvements: Are there any sidewalks, paving, curbs, gutters or driveways? None are shown on the drawings.




PRINTED ON RECYCLED PAPER

Response: There are no sidewalks, paving, curbs, or driveways for this project. The existing gutters over the entry doors are to be removed and re-installed after the new siding and fascia are installed.

Consider this information prior to submitting your bid on April 23, 2014.

Sincerely,

A handwritten signature in blue ink, appearing to read "George M. A. Macdougall". The signature is stylized and written over the printed name and title.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer