



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

April 14, 2014
Subject: **Islesboro Crew Quarters**
Federal Project No: 018407.00
State 018407.00
Amendment No. 2

David Bernhardt
COMMISSIONER

Dear Sir/Ms:

The following questions have been received:

Question: No exterior lights are shown on the plans, but are listed in the specs as to type. Where are they to be located on the building and how many will there be?

Response: There are 2 exterior lights, one at each entry door location. They are to replace the existing light fixtures currently in these locations.

Question: Interior lighting is listed as a Progress fixture, (typical). Will this be acceptable in the closet shown?

Response: Yes the Progress lighting fixture will be acceptable for the closet location

Question: Plans show us re-working the electrical feeder and service. Can we assume it is in conduit?


Response: Yes conduit will be required. It must also meet all local and State electrical codes

Question: What is the size of the electrical service?

Response: The existing service is 100 amp.

Consider this information prior to submitting your bid on April 23, 2014.

Sincerely,


George M. A. Macdougall P.E.
Contracts & Specifications Engineer

PRINTED ON RECYCLED PAPER