



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

April 23, 2014  
Subject: **Islesboro Crew Quarters**  
Federal Project No: 018407.00  
State Project No: 18407.00  
Location: Islesboro  
**Amendment No. 4**

Dear Sir/Ms:

Make the following change to the Bid Documents:

In the BID BOOK (page 10) "NOTICE TO CONTRACTORS", **CHANGE** the bid opening date in the first paragraph from "April 23, 2014" to read "**April 30, 2014**". Make this change in pen and ink.

In the Bid Book, (pages 19), **REMOVE** "Proposal Schedule of Items" 1 page dated 3/20/2014 and **REPLACE** with the attached new Proposal Schedule of Items" 1 page dated 4/23/2014

In the Bid Book (page 55), "SPECIAL PROVISION, SECTION 815, Buildings, Construction", **ADD** the following at the end of the section in pen and ink.

**"The Department will direct the Contractor to use self-adhesive membrane or taping of existing plywood edges as shown on plan Sheet 5 based on conditions determined during construction. The Department may increase, decrease or eliminate the Pay Item quantities and no adjustments to unit prices shall be made."**

In the Bid Book (page 59), "SPECIAL PROVISION, SECTION 815, Buildings, Method of Measurement" **ADD** the following at the end of the section in pen and ink.

**"Option #1: The self-adhesive membrane will be measured by the square foot along the entire sheathed wall surface of the existing building, complete, in place and accepted."**

**Option #2: The taping of existing plywood edges will be measured by the linear foot along seams of abutting existing wall sheathing panels, complete, in place and accepted."**

In the Bid Book (page 59), "SPECIAL PROVISION, SECTION 815, Buildings, Basis of Payment" **ADD** the following at the end of the first paragraph in pen and ink.

**"The accepted item for self-adhesive membrane will be paid for at the contract unit price per square foot."**



PRINTED ON RECYCLED PAPER

**The accepted item for taping existing plywood edges will be paid for at the contract unit price per linear foot.**

In the Bid Book (page 59), "SPECIAL PROVISION, SECTION 815, Buildings, Basis of Payment" **ADD** the following pay items at the end of the section in pen and ink.

<b>815.01</b>	<b>Building Item - taping</b>	<b>Linear Foot</b>
<b>815.00</b>	<b>Building Item - membrane</b>	<b>Square Foot</b>

On plan sheets:


On plan Sheet 5 Titled "Building Sections", Section B, the note "PROVIDE HENRY BLUESKIN VP 160 SELF ADHESIVE MEMBRANE OVER ENTIRE EXISTING WALL SHEATHING SURFACE (SEE ALTERNATE #1 BELOW IF EXISTING SURFACE IS PLYWOOD)" should be **REPLACED** in its entirety with "**OPTION #1: PROVIDE HENRY BLUESKIN VP 160 SELF ADHESIVE MEMBRANE OVER ENTIRE EXISTING WALL SHEATHING SURFACE (SEE OPTION #2 BELOW IF EXISTING SURFACE IS PLYWOOD)**"

In the note below Section B, **REPLACE** "ALTERNATE #1" with "**OPTION #2**".

Make these changes in pen and ink.

Consider this change and information prior to submitting your bid on **April 30, 2014**.

Sincerely,



George M. A. Macdougall P.E.  
Contracts & Specifications Engineer

