



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

March 25, 2014
Subject: **Vinalhaven**
State WIN: 018407.00
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: Are the previous drawings from Nov. 2013 proposal to be used for this proposal? If not, will the drawings be available electronically?

Response: The drawings are now available for this current project on the web along with the project bid book.

Question: Would you consider converting the septic tank (to be abandoned) into a lift station to save money?

Response: The septic tank is not to be used as a lift station. A new grinder station is to be used as stated in the plans.

Question: Can all the trench HMA be transported in (1) working day by Ferry Service (approximately 3 dump truck loads)?

Response: All HMA can be transported in 1 day on the Ferry's as long as prior arrangements have been made with the Maine State Ferry Service and or Project Manager to schedule the trip(s).

Consider this change and information prior to submitting your bid on April 2, 2014.

Sincerely,

For

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER