STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

July 22, 2014
Subject: **Albion**
State WIN: 021210.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: One of the two culvert pieces are crushed due to the failure of the slope. Will there be an amendment to request contractors to include a 10' section of culvert in their bids?

Response: The Contractor will be required to replace the 10' section of culver as part of the contract.

Consider this change and information prior to submitting your bid on July 23, 2014.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer

PRINTED ON RECYCLED PAPER

THE MAINE DEPARTMENT OF TRANSPORTATION IS AN AFFIRMATIVE ACTION - EQUAL OPPORTUNITY EMPLOYER
PHONE: (207) 624-3000 TTY: 888-516-9364 FAX: (207) 624-3001