



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

October 15<sup>th</sup> 2014  
Subject: **Building construction**  
State WIN: 021243.00  
Location: **Augusta**  
**Amendment No. 1**

Dear Sir/Ms:


The following question has been received:

**Question:** With regards to the slab detail and the 8" curb on the edge of the slab, that's a bit tough to work with sometimes, is it permitted for a higher curb, maybe a 10" or a 12" curb?

**Response:** The contractor may provide a curb equal to or greater than 8"

Consider this change and information prior to submitting your bid on **October 29, 2014.**

Sincerely,

  
George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER