



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

December 3, 2014  
Subject: **steel fabrication**  
NO WIN: PH20141119SF  
Location: **Enfield**  
**Amendment No. 1**

Dear Sir/Ms:

The following questions have been received:

**Question:** Notes on drawing indicate “end trim bars are optional” – should this be included or not?

**Response:** End trim bars are not optional and are to be put on both ends as show in “Fabrication Section B-B” on the drawing.

**Question:** Notes on drawing refer to “Primer Paint” – please specify?

**Response:** Apply two coats of primer paint as specified in the MaineDOT Standard Specifications November 2014 Edition under Section 506 Zinc Rich Coating System, prior to shipping to Enfield, Maine.

Consider this information prior to submitting your bid on **December 10, 2014**.

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER