



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

June 5, 2015
Subject: Lg. Culvert Replacement
State WIN: 019260.00
Location: **Hallowell**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Will the department allow the use of a 18000lbs track paver with an 8' main screed that opens to 15'8" weiler p385?

Response: If the Contractor wishes to use an 8' paver, the Department will accept this machine however, if an 8' paver is used, the Department will require density testing on all pavement placed by the 8' paver.

Consider this information prior to submitting your bid on **June 10, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER