



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

June 12, 2015
Subject: mill & fill
State WIN: 020256.00
Location: **Portland**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Would the department consider changing the testing method to a Method D for the Item 403.213 as it will be placed in narrow areas for the median removal?

Response: No, the acceptance method for Item 403.213 shall remain as Method B due to the fact that this item will be used in areas that will be considered mainline travelway after construction.

Consider this information prior to submitting your bid on **June 17, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER