



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

March 12, 2015
Subject: **bridge deck replacement**
State WIN: 020482.00
Location: **Unity**
Amendment No. 1

Dear Sir/Ms:

Make the following change to the Bid Documents:

In the Contract Book:

On page 14, "NOTICE TO CONTRACTORS", in the first paragraph, within the sentence that starts with "The lowest responsive bidder must have completed, or successfully complete a bridge, highway, or project..." **DELETE** the word "highway". Make this change in pen and ink.

The following question has been received:

Question: Will the Department allow the use of a lightweight vibrating screed for the two deck placements on this project?

The width seems to be outside the parameters set forth in 502.13 B of the standard specifications however we feel that this application would be ideal and would save significant money in the process.

Response: MainedOT will not allow the use of a lightweight vibrating screed to place the deck on this project.

Consider this information prior to submitting your bid on **March 18, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER