



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

January 26, 2015
Subject: **intersection improvements**
State WIN: 020571.00
Location: **Trenton**
Amendment No. 2

Dear Sir/Ms:

The following questions have been received:

Question: Is the pavement to be removed in the box cut section figured in the common excavation item?

Response: Yes, the common excavation quantity includes pavement removed in the box cut sections.

Question: What is the removing pavement surface item (202.202) to be used for?


Response: Item 202.202 Removing Pavement Surface is to be used for pavement milling as required to achieve the proposed roadway cross slope.

Question: The one test boring shows no refusal. Is there other documentation supporting the 50 c.y. of rock excavation?

Response: No there is no other documentation for subsurface information.

Consider this information prior to submitting your bid on **January 28, 2015**.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER