STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

October 23, 2015
Subject: Culvert Replacement
State WIN: 021450.00
Location: **Manchester**
**Amendment No. 1**

Dear Sir/Ms:

The following questions have been received:

Question: I've been talking to one of the manufacturers for the Arch CMP. They have asked if the structure is a 12 Gage Aluminized Type II Arch CMP or a 12 Gage Polymer Coated Arch CMP? There is enough of a difference in pricing that I would like to know what the State wants for an Arch CMP.

Response: The structure is to be the 12 Gage Polymer Coated Arch CMP.

Question: After visiting the site I have a concern. Has or will MaineDOT talked with the golf course about the possibility of moving the tee area during the few days that the contractor needs to complete the work (at least during the 45 hour closure period). The downstream end is in direct line with an errant tee shot.

Response: The Department will discuss all project related safety concerns with the Golf Course before the project begins.

Consider this change and information prior to submitting your bid on **November 4, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer

PRINTED ON RECYCLED PAPER

THE MAINE DEPARTMENT OF TRANSPORTATION IS AN AFFIRMATIVE ACTION - EQUAL OPPORTUNITY EMPLOYER
PHONE: (207) 624-3000 TTY USERS CALL MAINE RELAY 711 FAX: (207) 624-3001