STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

June 18, 2015
Subject: culvert replacement
State WIN: 022548.00
Location: **Southport**
**Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

**Question:** Will the use of a Weiler p385 paver with 8' main screed be allowed on this job?

**Response:** If the Contractor wishes to use an 8' paver, the Department will accept this machine however, the Department will require density testing on all pavement placed by the 8' paver.

Consider this information prior to submitting your bid on **June 24, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer