



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

March 23, 2015
Subject: **steel fabrication**
NO WIN: PH020504.00
Location: **Passadumkeag**
Amendment No. 2

Dear Sir/Ms:

The following question has been received:

Question: I'd asked about replacing the L4" x 3-1/2" x 7/16" with some 4" x 3-1/2" x 1/2" in the previous FAX. Your answer was that it must be L4" x 3-1/2" x 7/16". The problem is that I can't find a supplier who will furnish that thickness, so I again request that it be changed to 1/2" thick.

Response: The 4" x 3-1/2" x 1/2" angles will be allowed as a substitute for the 4" x 3-1/2" x 7/16" angles.

Consider this information prior to submitting your bid on **April 1, 2015**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER