STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

March 1, 2016
Subject: Highway Reconstruction
State WIN: 017890.00
Location: **Thomaston**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Would slipform curb on binder be an acceptable alternative to the type 3 bituminous curb?

Response: Slip form can be used for Type 3 Bituminous.

Question: Can the DOT allow Sanitite HP (Dual & Triple Wall Polypropylene meeting AASHTO M330) to be utilized for the 15", 18" and 36" Class III RCP that is specified on the project? Class III RCP and polypropylene are both approved under Option III.

Response: No, polypropylene pipe is not allowed on this road classification.

Consider this change and information prior to submitting your bid on **March 9, 2016**

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer