



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

March 21, 2016  
Subject: Milling/Overlay, Bridge  
Work with Drainage & Safety  
Improvements  
State WIN: 018987.00 & 20369.00  
Location: **Farmington & Strong  
Amendment No. 2**

Dear Sir/Ms:

The following questions have been received:

Question: Would slipform curb be an acceptable alternative to Curb type 3?

Response: No, because concrete slip form curb would not match existing curb

Question: In reference to sheet no 2, bid book page 50, note 5 which item is the concrete protective coating paid?

Response: In accordance with Special Provision 520, Heavy Duty Joint, basis of payment, Protective Coating shall be incidental to the Bridge Joint Modification Item 520.245.

Question: In reference to item 202.202 removing pavement surface, is milling of the bridge deck pavement allowed?

Response: Yes, in accordance with Standard Specification 202.061, Removing Pavement Surface, a power operated milling machine is allowed.

Consider this change and information prior to submitting your bid on **March 30, 2016**.

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER