



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Paul R. LePage  
GOVERNOR

David Bernhardt  
COMMISSIONER

January 7, 2016  
Subject: Intersection Reconstruction  
State WIN: 020559.00  
Location: **South Berwick**  
**Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

Question: I have just downloaded the plans and specs for the above referenced project. I am unfamiliar with bid item 603.55 Concrete Pipe Ties and also the unit of measurement (GP). Can you help me with a description and/or spec section that speaks to this item?

Response: This item is included in the updated 2014 Standard Specifications and Details, and had not been in the 2002 Edition. In the MaineDOT Standard Specification November 2014 Edition, Section 603.11 Method of Measurement, it states; Concrete pipe ties shall be measured per Group (2 ties per Group). Also there are standard details 603(10), 603(11) and 603(12) for the Concrete Pipe ties, in the MaineDOT Standard Detail 2014 Edition, Division 600 Miscellaneous Construction.

Consider this change and information prior to submitting your bid on **January 27, 2016**

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER