



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

January 12, 2016  
Subject: Intersection Reconstruction  
State WIN: 020559.00  
Location: **South Berwick**  
**Amendment No. 2**

Dear Sir/Ms:

The following questions have been received:

Question: Will the DOT allow the use of Sanitite HP polypropylene pipe as an alternate to the 15", 18", and 36" RCP class III on the project?


Response: No, polypropylene pipe is not allowed on this road classification.

Question: The "stockade" fence detail shows a 6 foot high vinyl privacy fence with 6" square posts over steel posts. We have not been able to find posts that would meet this specification. Would you accept 5" square posts with aluminum inserts?

Response: Yes, 5" square posts with aluminum inserts would be considered an acceptable alternative.

Consider this change and information prior to submitting your bid on **January 27, 2016**

Sincerely,

  
George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER