



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

August 22, 2016
Subject: Building Demolitions
State WIN: 021162.16D
Location: **Region 2**
Amendment No. 2

Dear Sir/Ms:

The following question has been received:

Question: My 2 questions, are there any site visit planned or are we on our own. Also, any haz (asbestos or bulbs ballasts) that we need to contend with did not see any reports in the specs?


Response:

The Department has no scheduled site visits.

A consultant firm was hired to do a demolition asbestos survey meeting Maine DEP Demolition Survey requirements. The survey did not address any other regulated hazards. All of the buildings were inspected and no asbestos materials were detected. The roofing shingles on B36039 Rockport were tested and no other suspect materials were found. Asbestos surveys may not be able to identify all asbestos present throughout the facility.

Consider this information prior to submitting your bid on **August 31, 2016**.

Sincerely,


George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER