



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

July 1, 2016
Subject: Office Drainage & Water
Service
State WIN: 021162.16S
Location: **Scarborough**
Amendment No. 3

Dear Sir/Ms:

Make the following change to the Bid Documents:

In Amendment No. 2, the following question had been received but had an incorrect response:

Question: Could you please give us more information on the water proofing membrane you want? All the listed companys list many different products. If you want as specific product will you please give us a product number you approve.

Amendment No. 2 Response: ~~The product must meet ASTM C386 Standard Specification for high solid content, cold liquid-applied elastomeric Waterproofing Membrane. Brands that provide a product that achieve this include, but are not limited to, Sonoshield, TREMproof, or Protesheild.~~

Corrected Response: The product must meet ASTM C836 Standard Specification for high solid content, cold liquid- applied elastomeric Waterproofing Membrane. Brands that provide a product that achieve this include, but are not limited to, Sonoshield, TREMproof, or Protesheild.

Consider this change and information prior to submitting your bid on **July 6, 2016.**

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER