



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

August 18, 2016
Subject: Wearing Surface
Replacement on Two Bridges
State WIN 021551.00 & 021556.00
Location: **Portland & Falmouth**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Can the five day duration for running traffic on the milled surface be waived for this project due to the unknowns of deck patching?

Response: If deck patching is required then the five day duration for running traffic on the milled surface will be waived and the Contractor will submit to the Resident, a proposal outlining the amount of time that traffic will be allowed to run on the milled surface, for the Resident's review and approval.

Consider this information prior to submitting your bid on **August 24, 2016**.

Sincerely,

A handwritten signature in black ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER